



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, CENTRAL LABORATORY
Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No: Lab/Bact/2022-23/ 1295

Dated: 26/05/22

To
The Principal,
L.B.S. Public School,
Sector-5, Pratap Nagar,
Tonk Road, Jaipur-302003

Not valid for Water
Quality Legal Case

The sample was not collected
by this laboratory.


Distt: Jaipur

Tehsil: Jaipur

Name of Sample Taker - Sh. Ashish

Reference - Your Application on dated 24.05.2022
GRN NO. - 62564822 Paid on Date 24.05.2022

Sample No.	Date of Collection	Date of Examination	Residual Chlorine mg/l	Area	Particulars of Samples	Coliform Organisms MPN/100 ml	E-Coli Organism (MPN)	Remarks (Satisfactory/ Unsatisfactory)
P:17 ----- 811	24.05.2022	24.05.2022	—	Pratap Nagar, Jaipur	T/W, L.B.S. Public School, Sector-5, Pratap Nagar, Jaipur	Nil	Nil	Satisfactory



26/5/22
Superintending Chemist
PHED, Laboratory, Jaipur
Dated:


No: Lab/Bact/2022-23/

Copy to:

1. The Chief Chemist, PHED, Rajasthan, Jaipur

~~Superintending Chemist
PHED, Laboratory, Jaipur~~


Chairman
LBS Public School,
Sec.-5, Pratap Nagar, JAIPUR


PRINCIPAL
L.B.S. PUBLIC SCHOOL
SECTOR-5, PRATAP NAGAR, JAIPUR

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2022-2023/ 1299

Date: 26/5/2022

To,

L.B.S. Public School,
Sector-5, Pratap Nagar,
Tonk Road, Jaipur.


The Sample was not Collected
by this Laboratory

Not Valid for water
quality Legal Cases

Date of Receipt 24-05-2022

Particulars			TW Water L.B.S. Public School, Sector-5, Pratap Nagar, Tonk Road, Jaipur.
value as per I.S.:10500/2012			
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			24-05-2022
Lab. Sample No.			P - 21
1. pH	6.5-8.5	6.5-8.5	7.41
2. Turbidity (NTU)	1	5	NIL
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O.
5. Total Alkalinity(as CaCo3) mg/l	200	600	570
6. Total Hardness (as CaCo3) mg/l	200	600	220
7. Calcium (as Ca) mg/l	75	200	40
8. Magnesium (as Mg) mg/l	30	100	29
9. Chloride (as Cl-) mg/l	250	1000	160
10. Nitrates (as NO3-) mg/l	45	45	45
11. Sulphate (as SO4-2) mg/l	200	400	200
12. Total Dissolved Solids mg/l	500	2000	1470
13. Fluoride mg/l	1.00	1.5	0.77
14. Iron mg/l	1.0	No Relaxation	NIL
15. Arsenic mg/l	0.01	No Relaxation	NIL

Remark- 1. All chemical parameters except pH are in mg/L
 2. Tested Results Relate only to The Samples send by you


 Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur


No: Lab/Sup.Chem. (HM) / Jaipur (City) /2022-2023/


Date:

Copy to:-

1. The Chief Chemist, PHED Raj. Jaipur

Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur


 Chairman
 LBS Public School
 Sec.-5, Pratap Nagar, JAIPUR


 PRINCIPAL
 L.B.S. PUBLIC SCHOOL
 SECTOR-5, PRATAP NAGAR, JAIPUR